



# नाशिक महानगरपालिका नाशिक

## फॉर्म 'सी'



सन १९४९ च्या दि बॉम्बे नर्सिंग होम्स रजिस्ट्रेशन  
अॅक्टच्या कलम ५ अन्वये दिलेले रजिस्ट्रेशन सर्टिफिकेट

दि बॉम्बे नर्सिंग होम्स रजिस्ट्रेशन अॅक्ट १९४९ अन्वये श्री. / श्रीमती डॉ. मि. मि. वा. वा. वा. आवारे,  
"श्री. स. ल. सुंगी आयुर्वेद महाविद्यालय, (मॅटर्निटी व नर्सिंग होम), कमल नगर, हिरावाडी, पंचवटी.  
येथील नर्सिंग होम / हॉस्पिटल / मॅटर्निटी होम रजिस्टर केले असून सदरचे नर्सिंग होम / हॉस्पिटल / मॅटर्निटी होम चालविण्यास परवाना  
देण्यात येत आहे.

रजिस्ट्रेशन क्र :	५६६	हॉस्पिटलसाठी	१७०	कॉट्स
		प्रसूतीसाठी	१०	कॉट्स
रजिस्ट्रेशन दि :	०९/०४/२०२९	इतर रूग्णासाठी	४०	कॉट्स
	ते ३१/०३/२०२४	अत्यावश्यक		कॉट्स
ठिकाण :	नाशिक,	एकूण	= २२०	



सर्टिफिकेट दिल्याचा दिनांक ५/१०/२०२९  
सदरचे सर्टिफिकेट चा कालावधी दिनांक ३१ मार्च २०२४ पर्यंत राहिल.

उपरोक्त कालावधीत वेळोवेळी B.M.W. चे नुतनीकरण व  
अग्निप्रतिबंधकचे बी फॉर्म सादर न केल्यास सदरचे नोंदणी  
प्रमाणपत्र रद्द समजण्यात येईल.

आरोग्य वैद्यकिय अधिकारी

नाशिक महानगरपालिका, नाशिक



# MAHARASHTRA POLLUTION CONTROL BOARD

Tel: 0253 - 2365150  
Fax: 0253 - 2365150  
Website: <http://mpcb.gov.in>  
Email: [ronasik@mpcb.gov.in](mailto:ronasik@mpcb.gov.in)

Udyog Bhavan, First Floor,  
Trimbak Road, Near ITI,  
Satpur, Nashik - 422007

ORANGE/S.S.I  
No:- Format1.0/RO/UAN  
No.0000147409/CO/2209000107

Date: 02/09/2022

To,  
M/s. Shree Saptashrunji Ayurved Hospital  
Kamal Nagar, Hirawadi, Panchavati, Nashik  
Tal and Dist Nashik



Your Service is Our Duty

**Sub: Combine Consent to operate and Bio-Medical Authorization under Orange Category for Hospital Activity.**

**Ref: Bio-Medical Authorization granted by the Board vide no 11.12.2015.**

Combined Consent to Operate and BMW Authorization.

For: Under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 6 of the Hazardous & Other Wastes (Management & Transboundary Movement) Rules 2016 and Bio-Medical Waste Management Rules, 2016 and amendment thereof is considered and the consent is hereby granted subject to the following terms and conditions and as detailed in the schedule I, II, III & IV annexed to this order:

- The Combined Consent to Operate and BMW authorization is granted upto: 31.03.2025**
- The capital investment of the project is Rs.2.0013 Crs. (As per C.A Certificate submitted by industry ).**
- The Consent is valid for the Activity of**

Sr No	Activity	Quantity	UOM
1)	Hospital		
a)	Beds	220	Nos
b)	Total Plot Area	4046.86	Sq.Mtrs
c)	Total Built up Area	5722.44	Sq.Mtrs

Conditions under Water (P&CP) Act, 1974 for discharge of effluent:

Sr No	Description	Permitted (in CMD)	Standards to Achieve	Disposal
1.	Trade effluent	0.0	As per Schedule -I	NA
2.	Domestic effluent	0.5	As per Schedule -I	The treated sewage shall be recycled for secondary purposes to the maximum extent and remaining shall be discharged on land for gardening within premise and remaining shall be disposed in sewerage system provided by local body. In no case, sewage shall find its way for gardening / outside hospital premises.

- Conditions under the Air (P& CP) Act, 1981 for air emissions:**

Sr.No	Description of stack / source	Number of Stack	Standards to be achieved
1	0	1	As per Schedule -II

6. Conditions under Hazardous & Other Wastes (M & T M) Rules 2008 for treatment and disposal of hazardous waste:

Sr No	Type of Waste	HW Category.	Quantity	UoM	Treatment	Disposal
1		NA	0	--NA--	NA	NA

7. Conditions about Non Hazardous Wastes:

Sr No	Type of Waste	Quantity	UoM	Treatment	Disposal
-------	---------------	----------	-----	-----------	----------

8. Treatment and Disposal of Biomedical Waste generated to CBMWTSDF:

Sr.No	Category	Type of Waste	Quantity not to exceed (Kg/M)	Segregation Color coding	Treatment & Disposal
1	Yellow	a) Human Anatomical waste	80.00	Yellow colored non- chlorinated plastic bags or containers	No onsite treatment of BMW is permitted. The above-mentioned Bio medical Waste shall be sent to Common BMW Treatment & Disposal facility authorized by MPCB i.e. CBMWTSDF
		b) Soiled Waste	127.00		
		c) Expired or Discarded Medicines	45.00		
		d) Chemical Liquid Waste	2700.00		
2	White (Translucent)	Waste sharps including Metals	35.00	Puncture proof, Leak proof, tamper proof container	No onsite treatment of BMW is permitted. The above-mentioned Bio medical Waste shall be sent to Common BMW Treatment & Disposal facility authorized by MPCB i.e. CBMWTSDF


9. PP shall comply the following guidelines published by the CPCB on February-2019 regarding handling of BMW for utilization

- HCE shall preferably handover Bio-medical wastes such as pleural fluid, ascetic fluid, HBsAG positive blood, placenta etc. to the Pharmaceutical industry / Biotechnology firms for production of drugs, reagent chemicals, markers etc. if any such as Pharmaceutical industry / Biotechnology firm approaches them for the same. If there are any difficulties in the matter, the same may be communicated to such firm and copied to the board also.
- HCE shall strictly follow the procedure for packaging & transportation of Bio-medical Wastes such as pleural fluid,ascetic fluid, HBsAG positive blood, placenta etc. to the Pharmaceutical industry / Biotechnology firms as per the guidelines of CPCB published in Feb-2019 for "Handling of BMW for utilization".
- HCEs shall submit the report to the Board office about type, quantity and frequency of handling over such BMW on yearly basis.
- Industry to enter into legal agreement with HCE's and inform the MPC Board and competent authority of State Public Health Department about such collection of BMW along with quantity and type of waste collected.
- In case of any technical difficulty towards handing over the required BMW, you shall inform to the Board accordingly.
- HCEs shall properly dispose and handover the waste to authorised user / facilities having valid consent to operate from MPCB.

10. This consent is issued subject to conditions mentioned below:



- a. The "authorized Person" shall comply with provisions of the Environment (Protection) Act, 1986, and the Rules made there under.
  - b. Any unauthorized change in equipment or working conditions as mentioned in the application by the person authorized shall constitute a breach of this Authorization.
  - c. You shall submit details of Management and Handling of outdated, discarded, unused Cytotoxic drugs generated in the Cancer centers, research and health care in the format prescribed by CPCB which is available on www.cpcb.nic.in alongwith Annual Report to MPCB with a copy to CPCB before 31st January every year.
  - d. You shall manage the Mercury Waste in the HCE in environmentally sound manner (including storage, spilled collection, transportation and disposal) as per CPCB guidelines published on CPCB website www.cpcb.nic.in dated: 07.09.2010 as detailed in document entitled "Environmentally Sound Management of Mercury Waste in Health Care Facilities"?.
  - e. You shall ensure phase out of chlorinated plastic bags, gloves and blood bags by HCEs within two years.
  - f. You shall establish Bar code system within one year.
  - g. You shall ensure that the liquid waste is treated and disposed by all the occupier or operator of a CBWTF in accordance with the Water Act, 1974;
  - h. You shall maintain day to day basis and display the monthly record Including Annual report on its website within two years from the date of Notification.
  - i. You shall submit separate Bank Guarantees towards compliance of condition mentioned at Annexure - IV to Regional Office, within 30 days.
  - j. You shall submit compliance of Bank Guarantee conditions every six months to Regional Officer, for verification purpose.
  - k. You shall submit application for renewal of Combined Consent and Biomedical Waste authorization before 120 days along with appropriate fees.
11. This Board reserves the right to review, amend, suspend, revoke etc. this consent and the same shall be binding on the industry.
  12. This consent should not be construed as exemption from obtaining necessary NOC/permission from any other Government agencies.



46373dce  
b33a6f0e  
98184d4f  
b2f33abb  
5b3c1b36  
c85549c8  
a16be972  
c4dd8cf7

**Signed by: Shri. Ravindra Andhale**  
Regional Officer  
For and on behalf of,  
**Maharashtra Pollution Control Board**  
ronashik@mpcb.gov.in  
2022-09-02 11:59:03 IST

**Received Consent fee of -**

Sr.No	Amount(Rs.)	Transaction/DR.No.	Date	Transaction Type
1	14500.00	TXN2208003636	30/08/2022	Online Payment
2	12500.00	TXN2208002279	22/08/2022	Online Payment

**Fees from UAN No.MPCB-BMW\_AUTH-0000016881 & MPCB-BMW\_AUTH-0000024882 has been totally utilized for this CCA, hence no fees is pending with the Board.**

**Copy to:**

1. Regional Officer, MPCB, Nashik and Sub-Regional Officer, MPCB, Nashik  
- They are directed to ensure the compliance of the consent conditions.
2. Chief Accounts Officer, MPCB, Sion, Mumbai

## SCHEDULE-I

### Terms & conditions for compliance of Water Pollution Control:

1. A] Generation - Nil  
B] Treatment - NA  
C] Disposal - NA
2. A] As per your application, you have provided Sewage Treatment Plant of designed capacity 1.0 CMD for the treatment of 0.5 CMD of sewage.  
B] The Applicant shall operate the sewage treatment system to treat the sewage so as to achieve the following standards.

1	pH	Not to exceed	6.5-9.0
2	Oil & Grease	Not to exceed	10
3	BOD (3 days 27oC )	Not to exceed	30
4	COD	Not to exceed	250
5	TSS	Not to exceed	100
6	Bio-Assay Test	Not to exceed	90% Survival of Fish after 96 hr. in 100% effluent

C] The treated sewage shall be recycled for secondary purposes to the maximum extent and remaining shall be discharged on land for gardening within premise and remaining shall be disposed in sewerage system provided by local body. In no case, sewage shall find its way for gardening / outside hospital premises.

3. The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification there of & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.
4. The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
5. The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Act, 1974 and as amended, by installing water meters and other provisions as contained in the said act:

Sr. No.	Purpose for water consumed	Water consumption quantity (CMD)
1.	Industrial Cooling, spraying in mine pits or boiler feed	0.00
2.	Domestic purpose	1.00
3.	Processing whereby water gets polluted & pollutants are easily biodegradable	0.00
4.	Processing whereby water gets polluted & pollutants are not easily biodegradable and are toxic	0.00
5.	Gardening	0

6. The Applicant shall provide Specific Water Pollution control system as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance/ CREP guidelines.





## SCHEDULE-II

### Terms & conditions for compliance of Air Pollution Control:

1. As per your application, you have provided the Air pollution control (APC) system and erected following stack (s) to observe the following fuel pattern:

Stack No.	Stack Attached To	APC System	Height in Mtrs.	Type of Fuel	Quantity & UoM	S%	SO <sub>2</sub>
0	0 0	0	0	0	0 --NA--	0.00	0.00

2. The applicant shall provide stack height of mtrs operate and maintain above mentioned air pollution control system, so as to achieve the level of pollutants to the following standards:

Total Particulate matter	Not to exceed	150 mg/Nm <sup>3</sup>
--------------------------	---------------	------------------------

3. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement/alteration well before its life come to an end or erection of new pollution control equipment.
4. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).
5. Conditions for D.G. Set

- a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
- b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
- c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
- d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
- e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use.
- f) D.G. Set shall be operated only in case of power failure.
- g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
- h) The applicant shall comply with the notification of MoEF dated 17.05.2002 regarding noise limit for generator sets run with diesel.

### SCHEDULE-III

#### Details of Bank Guarantees:

Sr. No.	Consent(C2E/C2O/C2R)	Amt of BG Imposed	Submission Period	Purpose of BG	Compliance Period	Validity Date
1	C2R	1,25,000	15 Days	Compliance of CCA	31.03.2025	31.07.2025

\*\* The above Bank Guarantee(s) shall be submitted by the applicant in favour of Regional Officer at the respective Regional Office within 15 days of the date of issue of Consent. # Existing BG obtained for above purpose if any may be extended for period of validity as above.

Statement of conditions to be complied and Bank Guarantee imposed to ensure timely compliance to be observed by:

Sr.No	Activity / Condition to be Complied	Compliance Timeline(Months)	Bank Guarantee Amount
1A	Operation and Maintenance		
1	To Segregate and Handle BMW as per Rule	Continuous	25,000
2	Towards Operation and Maintenance of STP/ETP to achieve prescribed discharge standards	Continuous	50,000
1B	Records		
1	To Maintain records of BMW and submission of Annual Report in Form -II before 31st January	Continuous	15,000
2	To maintain records of BMW material delivered to CBMWTSDF	Continuous	10,000
2	Performance		
1	To provide BMW separate storage facility as per guidelines of CPCB	Continuous	25,000

#### BG Forfeiture History

Srno.	Consent (C2E/C2O/C2R)	Amount of BG imposed	Submission Period	Purpose of BG	Amount of BG Forfeiture	Reason of BG Forfeiture
NA						

#### BG Return details

Srno.	Consent (C2E/C2O/C2R)	BG imposed	Purpose of BG	Amount of BG Returned
NA				



## SCHEDULE-IV

### General Conditions:

1. You shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
2. You should monitor effluent quality, stack emissions, noise and ambient air quality quarterly
3. You shall provide ports in the chimney/(s) and facilities such as ladder, platform etc. for monitoring the air emissions and the same shall be open for inspection to/and for use of the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
4. Whenever due to any accident or other unforeseen act or even, such emissions occur or is apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.
5. You shall provide an alternate electric power source sufficient to operate all pollution control facilities installed to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms and conditions of this consent.
6. You shall submit, the Environmental Statement Report for the financial year ending 31st March in the prescribed Form-V as per the provisions of rule 14 of the Environment (Protection) (Second Amendment) Rules, 1992 to Regional Office, , the 30th day of September every year.
7. You shall recycle/reprocess/reuse/recover Hazardous Waste as per the provision contain in the HW (MH&TM) Rules 2008, which can be recycled /processed /reused /recovered and only waste which has to be incinerated shall go to incineration and waste which can be used for land filling and cannot be recycled/reprocessed etc should go for that purpose, in order to reduce load on incineration and landfill site/environment.
8. You shall comply with the Hazardous Waste (M, H & TM) Rules, 2008 and submit the Annual Returns to RO- as per Rule 5(6) & 22(2) of Hazardous Waste (M, H & TM) Rules, 2008 for the preceding year April to March in Form-IV by 30th June of every year.
9. An inspection book shall be opened and made available to the Board's officers during their visit to the HCE.
10. You shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act, 1981 and Environmental Protection Act, 1986 and industry specific standard under EP Rules 1986 which are available on MPCB website ([www.mpcb.gov.in](http://www.mpcb.gov.in)).
11. You shall constitute an Environmental cell with qualified staff/personnel/agency to see the day to day compliance of consent & authorization condition towards Environment Protection.
12. Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers downstream of the terminal manholes. No effluent shall find its way other than in designed and provided collection system.
13. Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the HCE.

14. You shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
15. You should not cause any nuisance in surrounding area.
16. You shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
17. You shall maintain good housekeeping.
18. You shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a yearly statement to Regional Office by 30th September every year on available open plot area, number of trees surviving as on 31st March of the year and number of trees planted by September end.
19. The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
20. You shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. You will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
21. You shall submit Six Monthly statement in respect of obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can be downloaded from MPCB official site).
22. You shall submit official e-mail address and any change will be duly informed to the MPCB, forthwith.
23. You shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification dtd. 16.11.2009 as amended
24. You shall observe provisions of E-waste (Management and Handling) Rules 2011 and Battery Waste (Management and Handling) Rules 2001, as amended.

---

**This certificate is digitally & electronically signed.**

---





## नाशिक महानगरपालिका, नाशिक

संदर्भ :- वाचा :- महाराष्ट्र आग प्रतिबंधक व जीवसुरक्षा उपाययोजना अधिनियम २००६

— अग्निशमन व आग्निबाणी सेवा —

— अग्निप्रतिबंधक दाखला — (मॅटर्निटी व नर्सिंग होम)

दाखला देणेत येतो को डॉ. श्री. एस. बी. आहेर यांना त्यांची जागा स.नं. १९६/२/१२/२/२, पं. भुखंड क्र.०२, कमल नगर, हिरावाडी, पंचवटी, नाशिक. या ठिकाणी सदर इमारतीमधील (स्टिल्ट मजला करिता) येथे "मे. सप्तश्रृंगी आयुर्वेद हॉस्पिटल (मॅटर्निटी व नर्सिंग होम)" या व्यवसायासाठी खालील निम्नलिखित अटी-शर्तीच्या अधीन राहून अग्निप्रतिबंधक दाखला देणेत येत आहे.

**"जुना दाखला जमा करुन नविन दाखला देण्यात येत आहे"**

**-अटीशर्ती-**

- १) सदर दाखला हा फक्त मनपाने मंजूर केलेल्या नकाशावरहुकूम बांधकामासाठी दिलेला आहे. मंजूर कामाव्यतिरिक्त वाढीव बांधकाम व सामाजिक अंतरातील बांधकाम तसेच वापरात बदल केलेला असल्यास अशा अनधिकृत बदल झालेल्या इमारतीच्या भागास सदर दाखला लागू होणार नाही.
- २) दाखला घेतलेनंतर सदर इमारतीच्या बांधकामात वा वापरात बदल करण्यात आल्यास वा वाढीव बांधकाम केल्यास असा बदल मनपा नररचना खात्याकडुन मंजूर करुन घ्यावा लागेल तसेच केलेल्या बदलानुसार अग्निप्रतिबंधक व अग्निविमोचक उपाययोजनांमध्ये नियमानुसार फेरबदल करणे दाखलाधारकावर बंधनकारक राहिल.
- ३) तळघर (बेसमेंट) चा वापर मनपा विकास नियंत्रण नियमावलीनुसार अनुज्ञेय वापरांसाठीच करता येईल. अन्य वापरासाठी सदरचा दाखला लागू होणार नाही. सदर तळ घरांमध्ये निवासा साठी रूग्ण ठेवता येणार नाही.
- ४) ज्या जागेसाठी अग्निप्रतिबंधक दाखला दिलेला आहे त्या ठिकाणी असलेली अग्निप्रतिबंधक व अग्निविमोचक उपाययोजना, उपकरणे, बाहेर पडण्याचे मार्ग, पाण्याचा साठा, आपत्कालीन मार्ग इ. नेहमी सुस्थितीत ठेवणेची जबाबदारी महाराष्ट्र आगप्रतिबंधक व जीवसुरक्षा उपाययोजना अधिनियम २००६ नुसार मालक / भोगवटादार / दाखलाधारकाची असून त्याबाबत खात्री करुन घेणेकामां वर्षातुन किमान एक किंवा दोन वेळा अचानक भेटी देवुन तपासणी करणेचे अधिकार राखुन ठेवलेले आहेत.
- ५) महाराष्ट्र आगप्रतिबंधक व जीवसुरक्षा उपाययोजना अधिनियम २००६ मधील कलम ३ नुसार सदर ठिकाणी खालील प्रमाणे अग्निविमोचक व अग्निप्रतिबंधक उपाययोजना करणे बंधनकारक आहे.
- ६) सुचित केलेनुसार योग्य ती उपाययोजना केलेली नसल्यास अथवा केलेली उपाययोजना वापरण्यास योग्य सुस्थितीत ठेवलेली नाही असे निदर्शनास आल्यास अग्निशामक दलाने दिलेल्या मुदतीत सदर उपाययोजना सुस्थितीत दाखला धारकावर बंधनकारक राहिल. तसे न केल्यास सदर दाखलाधारकांकडुन नियमानुसार दंड वसूल करणेत येईल किंवा महाराष्ट्र आगप्रतिबंधक व जीवसुरक्षा उपाययोजना अधिनियम २००६ मधील कलम ८, ३६, ३८ नुसार कारवाई करणेत येईल.
- ७) महाराष्ट्र आगप्रतिबंधक व जीवसुरक्षा उपाययोजना अधिनियम २००६ मधील कलम ३ (३) नुसार आगप्रतिबंधक व जीवसंरक्षक उपाययोजना दुरुस्त व कार्यक्षम असलेबाबतचे विहीत नमुन्यातील प्रमाणपत्र ("बी फार्म") लायसन्स प्राप्त अभिकरणाकडुन प्राप्त करुन अग्निशामक विभागाकडे वर्षातुन दोन वेळा जानेवारी व जुलै महिन्यामध्ये सादर करावे लागेल.
- ८) अस्तित्वात अलेल्या अग्निप्रतिबंधक व अग्निविमोचक उपकरणे व यंत्रसामुग्रीच्या वापराबाबत दाखलाधारक व सदर ठिकाणी काम करणारे कर्मचारी यांना प्रशिक्षण माहिती असणे आवश्यक आहे.

उपरोक्त अटीचा भंग झालेचे निदर्शनास आल्यास सदरचा दाखला कोणतीही पुर्वसुचना न देता रद्द करणेत येईल.

हा दाखला दिनांक- ३१/१२/२०२१ पावेतो अंमलात राहिल.

दिनांक- २३/०३/२०२१



दाखला फि :-

बुक नं. ७७६१ पास नं. ०१ रुपये- ११,६८६/- दिनांक- १२/०८/२०२३

वार्षिक फि :-



-नूतनीकरण तपशिल-

अ.नं.	वर्ष	वार्षिक फी र.र.	फी भरलेचा तपशिल बुक नं./पा.नं. दिनांक	तपासणी केलेबाबत अनुज्ञाप्रीधारक अभिकर्ता यांचा दाखला दि.	सही
१)	२०१९ २०२० २०२१	३,३६०/-	बुक नं ८०३९ पास नं ३७ दि २३/३/२०१९	मेसर्स स्नेहा एरर प्रापजेस डि फार्म दि १०/३/२०२१	 २१/३/२०२१ मुख्य अतिरिक्त अधिकारी शासिक महानगरपालिका, नाशिक
२)	२०२२	१०००/-	बुक नं ५३७ पास नं ०३२ दि २१/१०/२०२२	मेसर्स स्नेहा एरर प्रापजेस डि फार्म दि १८/११/२०२२ "बी" फार्मची नोंद घेतली	 १८/१२/२०२२ मुख्य अतिरिक्त अधिकारी शासिक महानगरपालिका, नाशिक





# NASHIK MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

E mail :- cfo@nashikcorporation.in

Office of the Chief Fire Officer

DATE: 21/04/2022

Ref. No: NMC / FIRE / WS / H / Edu.- 01 / 2022;

To,

M/s. Shree Saptshrungi Shikshan Sanstha Nashik Through Chairmen  
Mrs. Hingauri B. Aber, Mr. Balasaheb Sonuji Aber & Gayatri B. Aber  
C/o Shri. Dhananjay M. Shinde, Architect, Nashik.

Sub: Requirements under Maharashtra Fire Prevention & Life safety Measures Act, 2006 for construction of Educational (Institutional) Building, in P. No. 1/82, S. No. 207/1/2, 211/1, Nashik Shivar, Nashik.

Ref:

1. Approval dated 30/08/2021 from Town Planning Deptt, NMC
2. NMC Commencement Certificate No.LND/BP/C1/344/2021, Date: 30/08/2021,
3. Fire Prevention Fund Rs.94,922/- (Fire Fund Rs.90,402/- + Inspection Fee Rs.4,520/-)  
Paid wide Book No.822; Pass No.000008; dated 20/04/2022

M/s. Shree Saptshrungi Shikshan Sanstha Nashik Through Chairmen Mrs. Hingauri B. Aber, Mr. Balasaheb Sonuji Aber & Gayatri B. Aber, has decided to construct a Educational (Institutional) Building, in P. No. 1/82, S. No. 207/1/2, 211/1, Nashik Shivar, Nashik, submitted municipal drawings after scrutiny from Town Planning deptt. to this office through C/o Shri. Dhananjay M. Shinde, Architect, Nashik.

The details of the building are as follows,

The building abuts on **18.00** meter wide road

#### BUILDING DETAILS

Area of construction (Built up area of Building):	2260.06 sq. mtr.
Height of Building:	18.94 mtr
Type of occupancy:	Educational (Institutional)
Number of floors:	Ground + 4 floors
No. of staircases required:	As per DC Rule 2020 No. 9.28.7
Travel Distance :	As per DC Rule 2020 No. 9.28.4

#### SPECIAL REQUIREMENTS:-

As the proposed building is a Special buildings / Educational building as specified in D.C. Rule No. 6.2.6.1, Fire protection rules and regulations as specified in National Building code of India-2016- Part IV, (Fire and Life Safety) and Maharashtra Fire Prevention & Life safety Measures Act, 2006 become applicable as below,

#### 1. ACCESS & TURNING CIRCLE FOR FIRE BRIGADE APPLIANCES:

- 1.1 All entrances & exit gates for the complex shall be min. of 4.5-meter width and height.
- 1.2 Courtyard of the complex shall be capable of taking the weight of Fire Appliances weighing nearly 45 tones.
- 1.3 As a School building, open spaces on its all side shall be of **6.00 meter** width ( Minimum) and shall be free of obstructions and shall be motorable for movement of Fire appliances, No parking is permissible in that area.
- 1.4 Balconies / Porches / Garages which will reduce the side marginal distance less than **6.00 mtrs** will not be allowed.

#### 2. STAIRCASES:

- 2.1 As per DC Rule No. 9.28.8.
- 2.2 Width of any staircase or exit shall not be less than **2.00 mtrs.**
- 2.3 Permanent ventilation at the top of staircase shaft shall be provided and is shall be not less than 5 % of the cross sectional area of the staircase.
- 2.4 Gas pipeline, Air condition ducts, Electrical Ducts etc shall not be passed through staircase enclosure.
- 2.5 Staircase on external walls of the buildings shall directly open to exterior or interior open space or to an open space of safety.
- 2.6 The staircases shall be lighted and ventilated and the minimum size of opening on walls abutting to open space shall be minimum 0.5 sq. meters per landing.
- 2.7 No living space, store or other Fire risk shall open directly into the staircase.



- 2.8 Minimum headroom under the landing of the staircase shall be 2.2 Mt.  
2.9 Access to staircase shall be through a fire / smoke door of minimum 2 hours Fire Resistance rating.  
2.10 No combustible material shall be used for deduction / wall paneling in staircase.

### 3. ESCAPE ROUTES (CORRIDOR & LOBBIES):

- 3.1 The corridors and lobbies on each floor landings shall be ventilated directly to open air.  
3.2 Smoke stop doors in adequate quantity shall be provided across the corridors considering the travel distances.  
3.3 All exits and escape routes shall be free from obstructions. No flammable material shall be stored in corridors, lobbies or staircase landings.  
3.4 Lifts and escalators shall not be considered as escape routes or exits.

### 4. DOORS:

- 4.1 All doorways shall open outwards, away from room but shall not obstruct the travel passage along any exit.  
4.2 If numbers of student in a class exceeds 45, there shall be two doors to the class-room.

### 5. FIRE LIFT: (For buildings above 15 mtr in Height)

(Minimum one lift to be provided compulsorily)

- 5.1 All the floors shall be accessible for 24 hours by the lifts.  
5.2 The lift shaft shall not be surrounded by staircase.  
5.3 The lift machine rooms shall be separate and no other machinery shall be installed or no combustible material shall be stored in the lift machine rooms.  
5.4 Collapsible gates shall not be permitted for lifts, and shall be solid doors with fire resistance of not less than 1 hour.  
5.5 The lift shall conform to the provision in National Building Code - Part IV Annex 'C'.  
5.6 The lift shall have a floor area of not less than 1.4 sq. meters and loading capacity of not less than 544 kg (8 persons) with automatic closing doors of 0.8 meter width.  
5.7 The operation of the Fire lift shall be by simple toggle switch or two button switch situated in a glass fronted box adjacent to the lift at the entrance level. When the switch is on, landing call points become inoperative and the lift will be on car control, when the switch is off, the lift will return to normal working. The lift can be used by the occupants in normal times.  
5.8 The electric supply for fire lift shall be on a separate service from electric supply mains in the building and the cables run in a route safe from fire i.e. within the lift shaft.  
5.9 In case of failure of electric supply, it shall automatically trip over to alternate supply.  
5.10 The words "FIRE LIFT" shall be conspicuously displayed in Fluorescent paint on the lift landing doors at each floor level.  
5.11 The fire lift should be provided with a ceiling hatch for use in case of emergency, so that when car gets stuck up, it shall be easily openable.  
5.12 The speed of the Fire Lift shall be such that it can reach the top floor from ground level within 1 minute.

### 6. ALTERNATE SOURCE OF POWER SUPPLY (Compulsory): (NBC 2016-Part IV, clause C-1.15)

A stand by electric generator of sufficient capacity shall be installed to supply power to staircase and corridor lighting circuits, fire lift, the stand by fire pump, pressurization fans & blowers smoke extraction and damper system in case of failure of electric supply.

### 7. ELECTRICAL SERVICES:

- 7.1 The electric distribution cables / wiring shall be laid in separate duct. The duct must be sealed at every floor with non-combustible material having the same fire resistance rating as that of the duct.  
7.2 Medium and low voltage wiring running in shaft & false ceiling shall run in separate conduits.  
7.3 Water mains, telephone lines, gas pipes or any other service lines shall not be laid in the duct for electrical cables.  
7.4 Separate circuits for fire fighting pumps, lifts, staircase and corridors lighting and blowers for pressurizing system shall be provided directly from the main switch gear panel and these circuits shall be laid in separate conduit pipes, so that one circuit will not affect the other.  
7.5 Suitable circuit breakers shall be provided at appropriate points.  
7.6 No other storage except electrical meters and panel board shall be allowed in electric control room.





## 8. FIRE PROTECTION SYSTEM:

As per National Building code-2016, Part-IV & Maharashtra Fire Prevention & Life safety Measures Act, 2006 the following fire protection system will have to be installed for the safety of the building.

### 8.1

Sr.no.	Protection	Fire Protection Required		
		Requirements	Provision	Remarks
1.	Portable Fire Extinguishers	Required	IS: 2190	On each floor & in Lift machine room
2.	Hose Reel	Required	IS: 884 : 1985	On each floor
3.	Down Comer	Required		
4.	Yard Hydrant	Required	IS:3844:1989 & IS 13039:1991	
5.	Automatic Fire Detection & Alarm system.	Required	IS:2189: 1999	<b>Only MOEFA System</b>
6.	Terrace tank	Required 25,000 ltrs.		Separate from Domestic Water Tank
7.	Fire Pump	900 lpm elect. driven: - 1 no.		900 lpm @ 36mtr. Head
8.	Fire Brigade Connection for static water tank & for hydrant system.	Required	Near main entry gate.	At ground floor, @ 1.0 mtr above GL.
9.	Sign Indicators for all fire safety, safe evacuation of occupants in case of emergency signs	Required at Prominent Places		Sign indicators should provided at prominent places as per the guidelines given in IS:9457 for Safety color and Safety IS:12349 for Fire Protection Safety Signs IS:12407 for Graphics symbols for Fire Protection Plan.

### 8.2 Approval of Drawings of Fire Protection System:

Detailed drawings of Hydrant system, detection system & sprinkler system etc will be submitted for the approval of Fire Brigade department before starting of actual work.

## 9. FIRE DRILLS & FIRE ORDERS (Including EMERGENCY EVACUATION PLAN):

Fire notices / orders shall be prepared to fulfill the requirements of fire fighting and evacuation from the building in event of Fire and other emergency. The occupants shall be made thoroughly conversant with their actions in the event of emergency by displaying fire noticed at vantage points and also through regular training. Such notices should be displayed prominently in broad lettering.

**Emergency evacuation and disaster management plan shall be prepared and followed strictly.**

## 10. FIRE CONTROL ROOM:

There shall be a control room on the entrance floor of the building with communication system (suitable Public Address system) to all floors and facilities for receiving the message from different floors. Details of all floor plans along with the details of fire fighting equipment and installations shall be maintained in fire control room. The fire control room shall also have facilities to detect the fire on any floor through indicator boards connection; fire detection and alarm system on all floors. The maintenance of the various services and fire fighting equipments and installations in coordination with security, electrical and civil staff of the building shall be done periodically as per norms.

## 11. GENERAL CONDITIONS:

- 11.1 No flammable / explosive material shall be stored in the premises before prior permission from the concern department including Fire Brigade.
- 11.2 All fire fighting equipments shall be as per IS specifications bearing I.S.I. mark
- 11.3 Fire fighting systems shall be painted with PO red color.
- 11.4 Sign board such as 'No Smoking', 'Exit', 'Emergency Exit', 'Emergency Phone Nos.', 'First Aid Box', Fire orders/ drill instructions etc shall be provided at prominent places. They shall be painted in **Marathi, Hindi and English** with reflective / glow paint only.
- 11.5 While providing all fire and life safety provisions, the **National Building code of India 2016 - Part IV & Maharashtra Fire Prevention & Life safety Measures Act, 2006** will be strictly followed.



11.6 The undersigned reserves right to amend any additional recommendations deemed fit during final inspection due to statutory provisions amended from time to time and in the interest of the protection of life & property.

- Note:-
- i) Architects & Owner / builder are requested to read Following Requirements / terms and conditions carefully.
  - ii) If any of the Following requirements are not fulfilled or completed during construction, Final NOC from this department will not be issued.
  - iii) The License Agency who will install the fire Protection system will be responsible for servicing & maintenance of the system and to issue the 'Form B' certificate in January and July month of every year for next Five years.

Copy to;  
A.D.T.P / Executive Engineer (Town Planning Dept)  
Nashik Municipal Corporation.



  
CHIEF FIRE OFFICER  
Nashik Municipal Corporation





# Watergrace Products

COMMON BIO.MEDICAL WASTE MANAGEMENT AND TREATMENT FACILITY NASHIK

Near Kannamwar Bridge, Mumbai Agra Road, Dwarka Nashik – 422 001. ■ : (0253) 2970299

e-mail : [helpdesk@watergrace.com](mailto:helpdesk@watergrace.com), [website : www.watergrace.com](http://www.watergrace.com)

REF NO. :WGP/BMW/PANCHVATI/04/2023/5970

DATE :01-APR-2023

## CERTIFICATE

TO WHOM SO EVER IT MAY CONCERN

*This is to certify that Dr. Milind B. Aware, Shree Saptashrungi Ayurved Hospital, Kamal Nagar, Hirawadi, Panchavati, Nashik With 220 (Two Hundred Twenty) Beds. Strength is registered member of our Common Bio-Medical Waste Management Collection Transportation Treatment and Disposal Facility Nashik vide Registered Index No. 437575 Dated 1st.January. 2017. The said Health Care units giving us Biomedical Waste for disposal as per the Maharashtra Pollution Control Board (M and H) Rules.*

*This NCC is valid upto :31 Mar 2024, for 220 (Two Hundred Twenty) Beds.*



For Watergrace Products Nashik  
Authorized Signatory